





- | ITEM | MATERIAL |
|------|---|
| 1 | CLEAN-OUT RISER, SEE NOTE 1. |
| 2 | 45° BEND, LONG-RADIUS SWEEP. |
| 3 | 560-C-3250 CONCRETE COLLAR (ROUND). SEE NOTE 3. |
| 4 | 560-C-3250 CONCRETE COLLAR (SQUARE). |
| 5 | CONSTRUCT FRAME, COVER AND CONCRETE COLLAR PER "PAVED" OR "UNPAVED" CONDITION HEREON. |
| 6 | PRECAST BOX, FRAME AND COVER WITH MARKING AS SHOWN HEREON. ALHAMBRA #A-1240, NEENAH #R-1976, OR APPROVED EQUAL. |
| 7 | SOLVENT WELD X F.I.P.T. SCH. 40 ADAPTER. |
| 8 | PVC SCH. 40 STOPPER. M.I.P.T. PLUG WITH MALE SQUARE NUT. |

- NOTES:**
1. CONSTRUCT CLEANOUTS OF THE SAME DIAMETER (4", 6" OR 8") AND MATERIAL AS THE SEWER LATERAL.
 2. USE SDR 35 PIPE AND FITTINGS WHERE COVER OVER PIPE EXCEEDS 5-FT AND SDR 26 WHERE COVER IS 5-FT OR LESS.
 3. IF LOCATED IN CONCRETE PAVEMENT, CONSTRUCT 6" THICK ROUND COLLAR FLUSH WITH PAVEMENT.

SEWER LATERAL TERMINAL CLEANOUT

REVISION			APPROVED:			CITY OF CORONA	
NO.	APPROVED	DATE				12-18-2013	DATE
						12-16-13	DATE
			NELSON D. NELSON, PE, CITY ENGINEER TOM KOPER, PE, DISTRICT ENGINEER, DEPARTMENT OF WATER AND POWER				
							STD 307
							SHEET 1 OF 1